



**List of essential and non-essential items**

All essential items must be completed prior to requesting CCC inspection.

Subdivision: \_\_\_\_\_ Phase: \_\_\_\_\_

Developer: \_\_\_\_\_ Agreement No.: \_\_\_\_\_

Consulting Engineer: \_\_\_\_\_

**Documentation**

**Roads items:**

**Essential**

**Non-essential**

- Water Resources clearance letter
- Material compliance approval letter
- All compaction reports (send directly. to the senior compaction inspector at Calgary Roads Unit) letter required from compaction inspector noting that all compaction tests meet City compliance.

None

**Water Resources items:**

**Essential**

**Non-essential**

- All catch basins and ICD(s) installed,
- All watermains, main and hydrant valves are operable c/w rods to proper lengths.
- All hydrants are operable and accessible.
- Field orders resolved.
- Drop, sieve and proctor test results.

- Asphalt aprons to be installed.
- Concrete tests for catch basins.
- Repair broken storm back.
- Frame requires adjustment.
- Secure frame/storm back.
- Top steps to be installed.
- Install proper manhole cover.
- Install missing collar.
- Repair/replace broken collars/barrels.

**Note:** The concrete tests for catch basins are to be submitted to the Water Resources inspector within 90 days of the date of the CCC.

**Legend:**

- OK** - Indicates all City requirements have been complied with or the utility has been inspected and was installed to City specs, or that the issues were resolved.
- N/A** - Not applicable.
- X** - Indicates utility has been inspected and that all non-essential requirements must be resolved within 60 days of the CCC or if installed after September 15, prior to June 30, in the year following the date of the CCC application.